



C E R T I F I C A T E

Certificate No. 10-PPV-0003808/01-W01-TIC

WE HEREBY CERTIFY THAT THE PHOTOVOLTAIC MODULES WITH THE MODEL

GB72P6-240 (Tested Type)

<u>Tested Type</u>	<u>Cell Number</u>	<u>Cell Size</u>	<u>Cell Technology</u>	<u>Power [W]</u>
GB72P6-240	72	6"	Polysilicon	240

Types extended for similarity* without need of re-testing (according to IECCE "Retesting guideline"):

<u>Type</u>	<u>Cell Number</u>	<u>Cell Size</u>	<u>Power [W]</u>
GB72P6-XXX*	72	6"	from 240 to 280
GB60P6-XXX*	60	6"	from 200 to 240
GB54P6-XXX*	54	6"	from 185 to 200

MANUFACTURING & LICENSE HOLDER

GreenBrilliance Energy Pvt. Ltd.

A1/3-4 B IDC Industrial Estate (Gorwa), Vadodara, India 390 016

IS IN COMPLIANCE WITH THE REQUIREMENTS OF

IEC 61215 : 2005

Crystalline silicon terrestrial photovoltaic (PV) modules – Design qualification and type approval
&

EN 61730-1 / EN 61730-2 : 2007

Photovoltaic (PV) module safety qualification
To be used in plants at a total voltage up to : 1000 Vdc

AS RESULT OF THE TEST IN OUR APPOINTED LABORATORY

EA ACCREDITED LABORATORY N. 0192

**REPORT No. TIC-PVM01CdO08C360001, PVS01CdO08C360001
TIC-3185405LAX-001a**

&

THE INSPECTION ON THE DATE 01st November 2010 WITH

REPORT No. RFI-1209-PPV-TIC-0003808

First issuing 11.02.2010

Expiring date 30.09.2013

(Providing that the testing basis continues unchanged)

Notes: (*) The manufacturer declares that these products are constructed using the same materials, components and processes as the tested type GB72P6-240. Further details on certified models are reported on the attachment. Technical data, materials and components description are into the indicated test reports. Any changes of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. Suffix XXX indicates rated power. The certification is performed on tested model as complete certification **without Fire Test according to IEC 61730-2/MST 23**. This certificate is for type approval and based on voluntarily product test. The Manufacturing Inspection is conducted by TÜV INTERCERT on the base of the internal procedures.



DAT-ZE-030/09-00



Am Bonner Bogen 2, D-53227 Bonn,

01.10.2011 Dipl.-Ing. F. Sergizzarea

TÜV INTERCERT Certification Body